



Jabalpur Smart City Limited (JSCL)

Manas Bhavan Wright Town, Jabalpur, M.P-482001, www.jscljabalpur.org,
Contact: admin@jscljabalpur.org, ceojscl@mpurban.gov.in Mob .7611136800

Ref No: JSCL/2019/...724

Date - 17/09/2019

This is with reference to release of RFP of Design, Supply and Installation of tensile membrane roof covering with supporting system and related civil, electrical & Drainage works at Galana Hawker Zone (Kachpura), Jabalpur by ref no. JSCL/2019/606/ADM/62 dated 10/08/2019 on websites <https://www.mprenders.gov.in> and www.jscljabalpur.org. It is to be informed to all the bidders that there have been some amendments and changes proposed in the published documents. These are as mentioned

Corrigendum no 1

Sr. no	As per Tender Document	Should be read as
1	<p>Design, Fabrication, Supply & Installation at site of :- Steel work in built up tubular(SHS/RHS/CHS), MS rolled structural members such as Angles, Channels & Plates etc. including cutting, hoisting fixing in position, welded and bolted including special shaped washers etc. complete as per direction of Engineer in charge Hot finished welded type tubes, Confirming ERW Pipes "IS 1161 / IS 1239 YST 310/240" upto 350mm dia "IS 3589 YST 310/240"(for above 350mm dia) SHS/RHS "IS 4923" (TATA / JINDAL / BHUSHAN / SAIL) and plate as per "IS 2062 E250" all plates to be CNC profile cut, Steel work cost includes architectural covering with SS 316 sheet of the gutter ring, clits & insert tubes for light fixing, drainage pipe & electrical cable pipe to be GI with elbows and bends cladde with Fabric TYPE II PVC coated polyester, surface coating of "cross link PVDf" wt of 1050 GSM, Tensile strength of 430/430 Dan/5Cm, light transmittance of 8%, (Ferrari /Mehler or equivalent), Tensioned over steel frames with all fittings and fixtures such as catenary cables, membrane plates, swedge, fork etc. as per the direction of Engineer in Charge. inclusive of design, providing and fixing fabric with all necessary accessories as required as per approved design complete. (Material Specification :-Tie Cables Galvanized Steel Core (Make :- Usha Martin / Bharat Wire Rope etc.), Material of End terminals and Nut bolts SS 304, forged HDGI bow shackles, End plates Mild Steel with Hot dip galvanized along with powder coating, Fabric Fixing Nuts and bolts HDG with 80 microns all complete.</p>	<p>Design, Fabrication, Supply & Installation at site of :- Steel work in built up tubular(SHS/RHS/CHS), MS rolled structural members such as Angles, Channels & Plates etc. including cutting, hoisting fixing in position, welded and bolted including special shaped washers etc. complete as per direction of Engineer in charge Hot finished welded type tubes, Confirming ERW Pipes "IS 1161 / IS 1239 YST 310/240" up to 350mm dia "IS 3589 YST 310/240"(for above 350mm dia) SHS/RHS "IS 4923" (TATA / JINDAL / BHUSHAN / SAIL) and plate as per "IS 2062 E250" all plates to be CNC profile cut, Steel work cost includes architectural covering with SS 316 sheet of the gutter ring, clits & insert tubes for light fixing, drainage pipe & electrical cable pipe to be GI with elbows and bends cladde with Fabric PVC coated polyester, surface coating of "cross link PVDf" wt of 1050 GSM, Minimum Tensile strength of 5500/5500 N/5Cm, Minimum Tear strength 800/650 N, Minimum light transmittance of 6%, (Ferrari or Mehler or equivalent), Tensioned over steel frames with all fittings and fixtures such as catenary cables, membrane plates, swedge, fork etc. as per the direction of Engineer in Charge. inclusive of design, providing and fixing fabric with all necessary accessories as required as per approved design complete. (Material Specification :-Tie Cables Galvanized Steel Core (Make :- Usha Martin / Bharat Wire Rope etc.), Material of End terminals and Nut bolts SS 304, forged HDGI bow shackles, End plates Mild Steel with Hot dip galvanized along with powder coating, Fabric Fixing Nuts and bolts HDG with 80 microns all complete.</p>

<p>2</p> <p>Material The Fabric shall be of approved make procured from a single manufacturer meeting following parameters:</p> <table border="1"> <tr><td>Description</td><td>Minimum required parameters</td></tr> <tr><td>Yarn count:</td><td>High Tenacity Polyester Yarns, 1670 Dtex</td></tr> <tr><td>Coated fabric Weight</td><td>1050 gm/m²</td></tr> <tr><td>Tensile Strength Warp/ weft</td><td>6000 N/5600N/5CM</td></tr> <tr><td>Tear Strength Warp/ Weft</td><td>900/800N</td></tr> <tr><td>Flame Retardancy</td><td>B-s2-d0</td></tr> <tr><td>Surface Treatment (Top/Back)</td><td>PVDF/PVDF Coated</td></tr> <tr><td>Quality Management System</td><td>ISO 9001</td></tr> </table> <p>3</p> <p>Warranty: The tensile fabric roofing system shall have warranty for minimum 15 years as per manufacturer. The contractor shall provide original warranty certificate issued by manufacturer in the Name of Airport Authority of India of fabric mentioning the details of project.</p> <p>4</p> <p>Note – The structural member of the roofing should be uniform and the dia of tubular columns should be similar at every location. The Aesthetical values of the roofing should not be compromise at any level.</p>	Description	Minimum required parameters	Yarn count:	High Tenacity Polyester Yarns, 1670 Dtex	Coated fabric Weight	1050 gm/m ²	Tensile Strength Warp/ weft	6000 N/5600N/5CM	Tear Strength Warp/ Weft	900/800N	Flame Retardancy	B-s2-d0	Surface Treatment (Top/Back)	PVDF/PVDF Coated	Quality Management System	ISO 9001	<p>Material The Fabric shall be of approved make procured from a single manufacturer meeting following parameters:</p> <table border="1"> <tr><td>Description</td><td>Minimum required parameters</td></tr> <tr><td>Coated fabric Weight</td><td>1050 g/m²</td></tr> <tr><td>Tensile Strength Warp/ weft</td><td>5500/5500 N/5CM</td></tr> <tr><td>Tear Strength Warp/ Weft</td><td>800/650 N</td></tr> <tr><td>Flame Retrancy</td><td>EN13501-1</td></tr> <tr><td>Surface Treatment (Top/Back)</td><td>Cross link PVDF/ Back PVDF</td></tr> <tr><td>Quality Management System</td><td>ISO 9001</td></tr> </table> <p>Warranty: The tensile fabric roofing system shall have warranty for minimum 15 years as per manufacturer. The contractor shall provide original warranty certificate issued by manufacturer in the Name of Jabalpur Smart City Ltd of fabric mentioning the details of project.</p>	Description	Minimum required parameters	Coated fabric Weight	1050 g/m ²	Tensile Strength Warp/ weft	5500/5500 N/5CM	Tear Strength Warp/ Weft	800/650 N	Flame Retrancy	EN13501-1	Surface Treatment (Top/Back)	Cross link PVDF/ Back PVDF	Quality Management System	ISO 9001
Description	Minimum required parameters																														
Yarn count:	High Tenacity Polyester Yarns, 1670 Dtex																														
Coated fabric Weight	1050 gm/m ²																														
Tensile Strength Warp/ weft	6000 N/5600N/5CM																														
Tear Strength Warp/ Weft	900/800N																														
Flame Retardancy	B-s2-d0																														
Surface Treatment (Top/Back)	PVDF/PVDF Coated																														
Quality Management System	ISO 9001																														
Description	Minimum required parameters																														
Coated fabric Weight	1050 g/m ²																														
Tensile Strength Warp/ weft	5500/5500 N/5CM																														
Tear Strength Warp/ Weft	800/650 N																														
Flame Retrancy	EN13501-1																														
Surface Treatment (Top/Back)	Cross link PVDF/ Back PVDF																														
Quality Management System	ISO 9001																														

Replies to Pre-bid Queries

Sr. No	Ref Document / Page no./Clause	As per Tender Document	Bidder's query	Response
5	FINANCIAL BID 15.4 Page 12 of 86	The bidder shall have to quote rates inclusive of all duties, taxes, royalties and other levies except goods & services tax (GST). The amount of applicable GST will be paid separately to the contractor with each bill at the time of payment; and the employer shall not be liable for any duties, taxes (except GST) royalties and levies etc.	weather Rates are inclusive GST or exclusive GST.	As per Tender Document
6	EARNEST MONEY DEPOSIT (EMD) Page 12 of 86	17.1. The Bidder shall furnish, as part of the Bid, Earnest Money Deposit (EMD), in the amount specified in the Bid Data Sheet. 17.2. The EMD shall be in the form of Fixed Deposit Receipt of a scheduled Nationalised/commercial bank, issued in favors of the name given in the Bid Data Sheet. The Fixed Deposit Receipt shall be valid for six months or more after the last date	Would Companies registered under MSME be exempt from Paying EMD	No exemption

[Handwritten signatures and initials]

		<p>of receipt of bids. However, form(s) of EMD may be allowed by the employer by mentioning it in the Bid Data Sheet.</p> <p>17.3. Bid not accompanied by EMD shall be liable for rejection as non-responsive.</p> <p>17.4. EMD of bidders whose bids are not accepted will be returned within ten working days of the decision on the bid.</p> <p>17.5. EMD of the successful Bidder will be discharged when the Bidder has signed the Agreement after furnishing the required Performance security.</p> <p>17.6. Failure to sign the contract by the selected bidder, within the specified period, for whatsoever reason, shall result in forfeiture of the earnest money.</p>			
7	ANNEXURE Page 20 of 86	---C	<p>Experience of having successfully executed:</p> <p>a) Three similar works, each costing not less than the amount equal to 20% of the probable amount of contract during the last 3 financial years; or</p> <p>b) Two similar works, each costing not less than the amount equal to 30% of the probable amount of contract during the last 3 financial years; or</p> <p>c) One similar work of aggregate cost not less than the amount equal to 50% of the probable amount of contract in any one financial year during the last 3 financial years;</p>	<p>Instead of last 3 financial years, it should be during last 3 financial years ending previous date of last day of submission of bid</p>	Refer Sr.no. 14
8	-		<p>With reference to mentioned subject, we request yourself to kindly consider the experience of private clients for the mentioned name of work for good competition, as these type of works are mostly carried out in private buildings.</p>	-	Accepted – The experience of private work needs to verify by completion certificate, Work Agreement and TDS certificate of payments.
9	Point No. 15. FINANCIAL BID: Page 12 of 86,		<p>Relating to Financial Bid, it is mentioned that Rates are exclusive of GST</p>	<p>Does that mean, tender Estimated Value of Rs. 3.08 lacs are exclusive of GST ?</p>	<p>The Probable Amount of Contract is exclusive of GST.</p>
10	TENSIONED FABRIC Page 27 of 86		<p>The specs mentioned conflict with the specs mentioned in BOQ. Will the specs mentioned in BOQ prevail, as specs mentioned in BOQ give equal opportunity to all fabric manufacturers, as it is mentioned "FERRARI/MEHLER or Equivalent" Whereas the specs mentioned here on page 27 of 86 are in favour of only one company, named MEHLER, which is monopolistic in nature.</p>	-	As per the corrigendum mentioned Above

11	WARRANTY Page 28 of 86	The contractor shall provide original warranty Name of Airport Authority of India	It should be Jabalpur Smart City limited, instead of Airport Authority of India	As per the corrigendum mentioned Above
12	Annexure-C, PRE_QUALIFICATIONS CRITERIA, Page 20 of 86	Main Tender Document: In the Clause relating to Experience of Bidders, having successfully executed similar works during last 3 financial years,	Please add the condition the works completed up to previous day of last date of submission of tenders shall also be considered	Refer Sr.no. 14
13	-	If our company has done the similar work of some Govt Contractor then, whether we meet the eligibility criteria of your Bid, kindly inform	The item is non SOR due to which this item is not used in Govt Dept & it is used in private sector, so requested to kindly allow	Refer Sr.no. 8
14	-	we are hereby attaching the Annexure C Pre-qualification criteria Sheet of PWD Jabalpur tender for your Reference where the works experience of similar nature of last 5 years is required , but you are asking for last 3 years as you are following PWD Specification & General Conditions. for execution of works.	-	Accepted - The work experience should be during last 5 financial years ending previous date of last day of submission of bid

Munish

[Signature]

[Signature]