



Jabalpur Smart City Limited

2	1.4 list of recommended makes (pg 132)	Sr no	Vendor/Make	Please Remove "or equivalent" at Sr. No. 2, 3 & 5. Please Remove "Rehaya" and Add "Totetsu" at Sr. No. 3	Vendor/Make
		2	Pure Rain , Triveni ,SGB or equivalent		Pure Rain, Triveni, SGB or equivalent
		3	Sekisui, Polypipe, Rehaya or equivalent		Sekisui, Polypipe, Rehaya, Totetsu or equivalent
		4	Pure Rain ,Triveni ,SGB or equivalent		Pure Rain ,Triveni, SGB or equivalent
3	--	In various places the word is mentioned "Cross Wave" technology but it's not a technology it's a word used by a particular Manufacturer for copolymer-based rain water harvesting system.		Amend the Word crosswave and size of Co-polymer based RWH system.	Same as per RFP
4	--	Providing & Fixing of Co-polymer based rainwater harvesting structure including supply of cross wave of size 494 mm x 494 mm x220mm with minimum void ratio of 94.7% having a weight of 1.8 kg and spacers having size of 988 mm x 240 mm x 25 mm having a weight of 0.8 kg of approved make and arranging the same in as directed by the engineer -in-charge and in complete accordance to the design, drawings. The rates are inclusive of all necessary transportation, loading, unloading excise, etc as per entire satisfaction of Engineer -in-charge.		Providing & Fixing of rain gold Co-polymer based rainwater harvesting structure size 1000 mm x 1000 mm x250mm with minimum void ratio of 94.7% or having size 1000 mm x 500 mm x250mm of approved make and arranging the same in as directed by the engineer -in-charge and in complete accordance to the design, drawings and manufacturer's specification.	Same as per RFP

[Handwritten signature]

[Handwritten signature]



Jabalpur Smart City Limited

Office No JSCL/2019/ 136

Date-26/02/2019

This is with reference to release of RFP of "Design, Development and implementation of Rain Water Harvesting system based on Advance Rain Water Harvesting Technology at various locations in Jabalpur City including operation & maintenance of project for 5 years Jabalpur" by tender no JSCL/2019/89/ADM/2019/11 dated 05-02-2019 on websites <https://www.mptenders.gov.in> and www.jscljabalpur.org. It is to be informed to all the bidders that there have been some amendments proposed in the Key dates. These dates are mentioned below.

Bid Data Sheet	
Purchase of Tender and submission date	01.03.2019 - 28.02.19
Physical submission	04.03.2019 02.03.19
Technical Opening	04.03.2019 02.03.19

PRE-BID MEETING QUERY				
Meeting Date: - 15/02/2018				
Name of Project: - Design, Development and implementation of Rain Water Harvesting system based on Advance Rain Water Harvesting Technology at various locations in Jabalpur City including operation & maintenance of project for 5 years				
S.no	Clause as per Tender Document	As per RFP	Query	Should be Read As
1	1. Eligibility criteria for bidder: pre-qualifications criteria	The Lead Bidder or Consortium/ JV should have Average Annual Turnover of 30% of the Estimated Project Cost during the last three financial years FY 2015-16, 2016- 17, 2017-18 (as per the last published audited balance sheets)	"Please remove Lead Bidder"	Consortium/ JV should have Average Annual Turnover of 30% of the Estimated Project Cost during the last three financial years FY 2015-16, 2016-17, 2017-18 (as per the last published audited balance sheets)

Registered Office: Manas Bhawan, Wright Town, Jabalpur M.P 482001